



తెలంగాణ రాజ పత్రము
THE TELANGANA GAZETTE
PART-II EXTRAORDINARY
PUBLISHED BY AUTHORITY

No.15]

HYDERABAD, THURSDAY, FEBRUARY 1, 2018.

NOTIFICATIONS BY HEADS OF DEPARTMENTS, Etc.,

— x —

PUBLIC WORKS NOTIFICATIONS

TRANSMISSION CORPORATION OF TELANGANA LIMITED

Lr.No.CE/400kV/SE.PM-I/DE-2/ADE3/STPP/D.No.550/2018.

Transmission Corporation of Telangana Limited proposes 400kV Telangana STPP-I Power evacuation Scheme (2X800), with the erection of the following Transmission lines, Sub-stations and Bay extensions as detailed below. The Scheme is proposed for completion during the year 2018-2021 and will result in reduction of EHT transmission losses, improvement of voltage profiles & meets the additional load demand in the region and surrounding areas.

Telangana STPP-I Power Evacuation Scheme (2X800 MW)

1. 400/220kV Ramadugu SS with 2x500 MVA
2. 400kV QMDC line from Telangana STPP stage-I (2x800MW) to 400/220kV Ramadugu Substation (Multi Circuit Towers 6KM and Conventional Towers 49KM) - 55KM
3. 400kV QMDC from Telangana STPP stage-I (2x800MW) to 400kV Narsapur Sub-station -170KM.
4. 400kV Quad Feeder Bay extensions at 400kV Narsapur SS- 2 Nos.
5. LILO of both circuits of 220kV Durshed-Sircilla at 400/220kV Ramadugu Sub-Station on Multi-circuit towers -12KM
6. LILO of 220kV Malyalpalli-Bheemgal at 400/220kV Ramadugu Sub-Station -35KM
7. 220kV Single Moose DC Line from proposed 220kV Borampet Sub-Station to existing 220KV Miyapur Sub-Station-35KM
8. 220kV Single Moose DC Line from proposed 220kV Borampet Sub-Station to existing 220kV Shapurnagar Sub-Station-35KM
9. 220kV Bay Extensions at Miyapur SS-2Nos. Shahpurnagar SS-2Nos. and Borampet SS - 4Nos.

In exercise of the powers conferred vide G.O.Ms.No.115, dated 07-10-2003 of Government of Andhra Pradesh, TSTRANSCO or their authorized representatives shall have the powers for placing of the electric supply

lines or electric plant for the transmission of electricity or for the purpose of telephonic or telegraphic communications necessary for the proper co-ordination of works that a telegraphic authority possesses under the provision of the Indian Telegraph Act, 1885 (Central Act-13 of 1885).

Any person interested/aggrieved may make representation to the Chief Engineer/ 400 kv, TSTRANSCO, Vidyut Soudha, Khairatabad, Hyderabad - 500 082 within two (2) months from the date of publication of this notification.

Representations received after the due date will not be considered and TSTRANSCO will take-up the above works after due date with/without modification as it deems fit after making enquiry, if necessary.

Hyderabad,
25-01-2018.

(Sd/-),
Chief Engineer,
400kV

—x—